

Map ID
Direction
Distance
Elevation

MAP FINDINGS

Site

Database(s)

EDR ID Number
EPA ID Number

FG795
North
> 1
1.098 mi.
5796 ft.

84 AVENUE U PUMPING STA
84 AVENUE U PUMPING STA
NEW YORK CITY, NY

NY Spills **S102140942**
N/A

Site 1 of 2 in cluster FG

Relative:
Higher

Actual:
14 ft.

SPILLS:

Name: 84 AVENUE U PUMPING STA
Address: 84 AVENUE U PUMPING STA
City,State,Zip: NEW YORK CITY, NY
Spill Number/Closed Date: 9101139 / 1995-02-15
Facility ID: 9101139
Facility Type: ER
DER Facility ID: 111672
Site ID: 129552
DEC Region: 2
Spill Cause: Equipment Failure
Spill Class: D4
SWIS: 3101
Spill Date: 1991-04-28
Investigator: MANDALA
Referred To: Not reported
Reported to Dept: 1991-04-28
CID: Not reported
Water Affected: EAST RIVER
Spill Source: Institutional, Educational, Gov., Other
Spill Notifier: Responsible Party
Cleanup Ceased: 1995-02-15

Cleanup Meets Std: True
Last Inspection: Not reported
Recommended Penalty: False
UST Trust: False
Remediation Phase: 0
Date Entered In Computer: 1991-05-01
Spill Record Last Update: 1995-02-16
Spiller Name: Not reported
Spiller Company: NYCDEP
Spiller Address: Not reported
Spiller Company: 999
Contact Name: Not reported
DEC Memo: ""
Remarks: "PUMP FAILED,WORKING TO RESTORE SYSTEM BYPASSING WITH CHLORINATION OF THE OUTFALL,DEC NOTIFIED."

All Materials:

Site ID: 129552
Operable Unit ID: 954561
Operable Unit: 01
Material ID: 427273
Material Code: 0062A
Material Name: raw sewage
Case No.: Not reported
Material FA: Other
Quantity: -1.00
Units: Not reported
Recovered: .00
Oxygenate: Not reported